SPRINKLER LINE TESTER

DATE
: 11/23/2026 07:51 PM

SKU
: 19487

BRAND
: DIXON VALVE

MODEL
: SLT10050



** Referential image*
*** Some features may vary without prior notice. Sale subject to inventory availability*

Applications:
For installing the last sprinkler head on system branch lines, controls water flow for flushing or testing of the system. When the wet pipe sprinkler system operates, the water flow in the pipes is at a relatively low velocity. Friction loss increases with the age of the sprinkler piping, up to 100 percent after 15 years. The accumulation of sediment and foreign objects in sprinkler systems can be prevented by flushing the supply mains to the systems through the hydrants at least semiannually. The National Board of Fire Underwriters recommends that sprinkler branch line flow tests be conducted from the extremities of the branch lines (at the end of the sprinkler system) to determine obstructions in the lines and to clean them of sediments or foreign materials that may be carried into the system by the flow of water.

Specifications:
UL Listed
FM approved

Construction:
1/2" sprinkler head connection
1" NPSH male outlet with NPSH cap and chain
1" NPT female inlet

Safety notes:
WARNING: Cancer and Reproductive Harm- www.P65Warnings.ca.gov

2645 Executive Park Drive, Weston, Fort Lauderdale, FL 33331, EEUU
sales@kmxusa.us
www.kmxusa.us

TECHNICAL SPECIFICATIONS

Inlet	1" female NPT
Material	Brass
Outlet	1" male NPSH
Factory Part Number	SLT10050
Weight Lb	0.8150

KMX

2645 Executive Park Drive, Weston, Fort Lauderdale, FL 33331, EEUU
sales@kmxusa.us

www.kmxusa.us